Project, Hell D. Cryogonia Target	
Project: Hall D cryogenic rarget	
Tittle: General calculations for relief and stor	age pressures
Document Number: TGT-CALC-401-001	
Revision: Original	
Author: Dave Meekins	Date: 2/6/2012
Checked:	Date:
Approved:	Date:
Code(s) of Record: ASME B31.3 2010 ASME B31.12 2011 ASME BPVC VIII D1 2010	
Reference Codes API 520 API 521 NFPA 2,55,497 CGA 5	
Reference Drawings TGT-401-0001-1000	
Description: Hall D target relief calculations and voluvacuum in a cryomodule is used as a d loss in the H2 target. Assume gas as it consrvative. The target cell is made of steel. The cell will have the lowest des Weymouth friction factor will be used a inch NPS. Crane 410 is used as guidan	ume estimate. The Schneider MEMO for loss of esign basis to determine the heat load from IV t leaves the target is at 300K. This is overly kapton. Other system components are stainless ign pressure; it will drive the design. The is it is conservative for all pipe sizes less than 20 nce.

Design assumptions limits and set points for pressures	
$P_{set} = 30 \cdot psi$	Relief set pressure absolute
$P_{atm} \coloneqq 14.7 \cdot psi$	atm pressure absolute
$P_{cold} \coloneqq 18 \cdot psi$	assumed cold operating pressure absolute
$P_{max} \coloneqq 35 \cdot psi$	absolute design pressure of target cell
${P}_{plate} \coloneqq 16.7 \boldsymbol{\cdot} \boldsymbol{psi}$	absolute parallel plate set pressure. Parallel plate is at exit of H2 vent
$P_{over} \coloneqq P_{max} \cdot 1.16 = 40.6 \ psi$	max allowed overpressure by code for redundant relief paths

### Fluid Properties for H2, D2 and He:

Properties were determined for He at 5.2K and 35 psia where a test was performed on the JLAB Cryo modules. Properties of H2 were determined at 30 psia and 23 K which are the expected relief pressure and temperature respectively for the Hall D target

Moler masses of H2, D2 and He

$M_{u_0} \coloneqq 2 \cdot \frac{gm}{m}$	$M_{\rm D2} \coloneqq 4 \cdot \frac{gm}{2}$	$M_{H_{\alpha}} = 4 \cdot \frac{gm}{2}$
mol	mol	mol

Latent heat of H2, D2, and He

$$\lambda_{H2} \coloneqq 461 \cdot \frac{J}{gm} \qquad \qquad \lambda_{D2} \coloneqq 304 \frac{J}{gm} \qquad \qquad \lambda_{He} \coloneqq 21 \frac{J}{gm}$$

gas constants

$$R_{H2} \coloneqq 4124.3 \cdot \frac{J}{kg \cdot K} \qquad \qquad R_{D2} \coloneqq 2064 \cdot \frac{J}{kg \cdot K} \qquad \qquad R_{He} \coloneqq 2077.3 \cdot \frac{J}{kg \cdot K}$$

density of H2, D2 and He at 300K and 30 psia (P\_set)

$h_{167} kg$	a = 0.334	h = 0.3216, $kg$
$\rho_{H2300} = 0.107 \cdot \frac{1}{m^3}$	$\rho_{D2300} = 0.334 \cdot \frac{1}{m^3}$	$p_{He300} = 0.3310 \cdot \frac{1}{m^3}$

### TGT-CALC-401-001

$$\begin{array}{c|c} \text{density of H2, D2, and He at 289K (60 F) and 14.7 psia} \\ \hline \\ \rho_{H2ztd} \coloneqq 0.0850 \cdot \frac{kg}{m^3} & \rho_{D2ztd} \coloneqq 0.1698 \cdot \frac{kg}{m^3} & \rho_{Hestd} \coloneqq 0.1687 \cdot \frac{kg}{m^3} \\ \hline \\ \text{density of liquid H2 and D2 at the target operating temperatures and pressure} \\ \hline \\ \rho_{H2zup} \equiv 72.26 \cdot \frac{kg}{m^3} & \rho_{D2up} \coloneqq 167.4 \cdot \frac{kg}{m^3} \\ \hline \\ \text{densities of H2 and D2 at the target operating temperatures and pressure} \\ \hline \\ \rho_{H2}(T,P) \coloneqq \frac{P}{(R_{H2}\cdot T)} \\ \hline \\ \text{This group of constants are needed to scale the He loss of vacuum data from Schneider to the case of H2 \\ \hline \\ K_{H2} \coloneqq 0.0187 \cdot \frac{W}{m \cdot K} & \text{Thermal conductivity of H2 at film boiling condition} \\ \hline \\ K_{He} \coloneqq 0.0257 \cdot \frac{W}{m \cdot K} & \text{Thermal conductivity of He (at film boiling condition)} \\ \hline \\ K_{L2} \coloneqq 0.0137 \cdot \frac{W}{m \cdot K} & \text{est thermal cond of D2 at film boiling condition} \\ \hline \\ T_{H2} \coloneqq 2.3 \cdot K & \text{Film boiling test temp for He from Schnleider MEMO \\ \hline \\ T_{H2} \coloneqq 2.3 \cdot K & \text{Film boiling test temp for H2 at target vent condition} \\ \hline \\ T_{room} \coloneqq 300 \cdot K & \text{room temperature} \\ \text{Specific heats of H2} \\ \hline \\ c_{pH2} \coloneqq 0.143 \cdot 10^3 \cdot \frac{J}{kg \cdot K} & c_{pH2} \coloneqq 0.102 \cdot 10^5 \cdot \frac{J}{kg \cdot K} \\ \hline \\ \text{Specific heats of D2} \\ \hline \\ c_{eD2} \coloneqq 5186 \cdot \frac{J}{kg \cdot K} & c_{pD2} \coloneqq 7251 \cdot \frac{J}{kg \cdot K} \\ \hline \end{array}$$

Specific heats of He  

$$c_{eHe} := 3116 \cdot \frac{J}{kg \cdot K}$$
 $c_{pHe} := 5193 \cdot \frac{J}{kg \cdot K}$ 
Ratios of specific heats for H2, D2 and He  
 $k_{H2} := \frac{c_{pH2}}{c_{vH2}} = 1.402$ 
 $k_{D2} := \frac{c_{pD2}}{c_{vD2}} = 1.398$ 
 $k_{He} := \frac{c_{pHe}}{c_{vHe}} = 1.667$ 
viscosities of each gas at exit. The viscosity in the vent stack will vary from this by  
less than 1%
 $\mu_{H2300} := 0.8959 \cdot 10^{-5} \cdot Pa \cdot s$ 
visc of H2 at 300K and 30 psi  
 $\mu_{H2300} := 0.1993 \cdot 10^{-4} \cdot Pa \cdot s$ 
visc of H2 at 300K and 30 psi  
 $\mu_{D2300} := 1.39 \cdot \mu_{H2300}$ 
visc of D2 at 300K and 30 psi  
 $\mu_{D2300} := 1.39 \cdot \mu_{H2300}$ 
visc of D2 at 300K and 30 psi  
 $v_{soundH2} := 1321 \cdot \frac{m}{s}$ 
speed of sound in each gas
 $v_{soundH2} := 1020 \cdot \frac{m}{s}$ 
speed of sound in He at 300K and 30 psi  
 $v_{soundH2} := \sqrt{k_{L2}} \cdot \frac{P_{set}}{\rho_{D2300}} = 930.528 \frac{m}{s}$ 
estimated speed of sound in J2 at 300K and 30 psi from ideal gas model
Critical flow pressure ratios for H2, D2, and He. determined using the ideal gas assumptions similar to API 520 eq 3.1



$$V_{ent} := \frac{\pi}{3} \cdot (L_{ent} - 1.585 \cdot in) \cdot \frac{(D_1^2 + D_1 \cdot D_2 + D_2^2)}{4} \qquad \begin{array}{l} \text{displaced volume of} \\ \text{entrance tube} \end{array}$$
Fill and return leg tubes on cell D00000-03-00-2005. There are (3) tubes
$$D_{fill} := 0.375 \cdot in \qquad \text{Tube OD}$$

$$L_{fill} := 4.25 \cdot in \qquad \text{est length of tubes to fitting} \\ A_{fill} := \pi \cdot D_{fill} \cdot L_{fill} \qquad \text{area of one fill tube} \\ V_{fill} := \frac{\pi}{4} \cdot D_{fill}^2 \cdot L_{fill} \qquad \text{volume of one fill tube} \\ V_{fill} := \frac{\pi}{4} \cdot D_{fill}^2 \cdot L_{fill} \qquad \text{volume of one fill tube} \\ \\ tubing from condenser to cell (loop tubing) (2) tubes, supply and return to cell \\ \\ L_{loop} := 8 \cdot ft \qquad \text{estimated length of each} \\ \text{tube} \\ D_{ri} := 0.5 \cdot in \qquad \text{OD of supply} \\ A_{sup} := \pi \cdot D_{sup} \cdot L_{loop} \qquad \text{area of supply line} \\ A_{ri} := \pi \cdot D_{ri} \cdot L_{loop} \qquad \text{area of neturn line} \\ A_{loop} := \frac{\pi}{4} \cdot (D_{ri}^2 + D_{sup}^2) \cdot L_{loop} \qquad \text{volume of loop tubing} \\ \\ \\ Condenser \\ \\ L_{cond} := 4 \cdot in \qquad \text{length of condenser} \\ A_{cond} := \pi \cdot D_{cond} \cdot L_{cond} + 2 \cdot \frac{\pi}{4} \cdot D_{cond}^2 \qquad \text{surface area of ordenser} \\ V_{cond} := \frac{1}{2} \left(\frac{\pi}{4}\right) \cdot D_{cond}^2 \cdot L_{cond} \qquad \text{conservative estimate of H2} \\ \\ \end{array}$$



# Required Storage Capacity/Pressure:

500 gal propane tanks are readily available and reasonably priced. These will suit the needs of the target well.

Volumetric storage of the H2 and D2 inventory

$$\begin{split} n_{H2} \coloneqq V_{LH2} \cdot \rho_{H2op} \cdot \frac{1 \cdot mol}{2 \cdot gm} &= 33.618 \ mol & \text{moles of H2 in liquid} \\ n_{D2} \coloneqq V_{LH2} \cdot \rho_{D2op} \cdot \frac{1 \cdot mol}{4 \cdot gm} &= 38.94 \ mol & \text{moles of D2 in liquid} \\ V_{store} \coloneqq 500 \cdot gal & \text{ext H2 storage volume} \\ P_{op} \coloneqq P_{cold} & \text{operating pressure} \end{split}$$

### Storage pressure and amount of of H2 at room temperature

$$\begin{array}{ll} PH_{store} \coloneqq n_{H2} \cdot R \cdot \frac{T_{room}}{V_{store}} + P_{op} = 24.426 \ psi & \text{absolute storage pressure} \\ P_{stp} \coloneqq 14.7 \cdot psi & \text{standard pressure} \\ T_{stp} \coloneqq 20 \ ^{\circ}C & \text{stp temp} \\ L_{stp} \coloneqq \frac{PH_{store}}{P_{stp}} \cdot V_{store} \cdot \frac{T_{stp}}{T_{room}} = (3.073 \cdot 10^3) \ L & \text{stp liters of H2} \end{array}$$

### Storage pressure and ammount of D2 at room temperature

$$PD_{store} \coloneqq n_{D2} \cdot \mathbf{R} \cdot \left(\frac{T_{room}}{V_{store}}\right) + P_{op} = 25.443 \ psi \qquad \text{absolute storage pressure}$$
$$L_{stp} \coloneqq \frac{PD_{store}}{P_{stp}} \cdot V_{store} \cdot \frac{T_{stp}}{T_{room}} = (3.201 \cdot 10^3) \ \mathbf{L} \qquad \text{stp liters of D2}$$

### Relief load calculation:

The worst case relief mass flow will result from a loss of insulating vacuum (IV). Fire is not a consideration as the magnet bore and all target components with the exception of the cell are metal. Igniting the H2, D2 would require a system breach and preclude a relief. The mass evolution rates resulting from a worst case relief event are scaled from He test data for each species of gas. Extremely conservative assumptions of the exit temperature of the relieving gas (300K at boil point) are used.

Estimated heat load from loss of vacuum:

This is estimated from the heat loads measured and calculated for a vacuum loss in a cryomodule. This is from the MEMO by W.J. Schneider 1999. The calculated heat fluxes are as low as 8 kw/m<sup>2</sup> where 20 kW/m<sup>2</sup> to 35 kW/m<sup>2</sup> were determined from measurement. It has become standard practice to assume ~20 kW/m<sup>2</sup> for insulated surfaces and 38kW/m<sup>2</sup> for uninsulted surfaces. These assumptions are quite conservative. These values can be scaled to H2 by considering the thermal conductivity of the film layers (assuming that they have the same depth) and the temperature difference. The walls of the cell and target piping are assumed to have no thermal resistance. For Helium from the test data we have conservatively

$$\begin{split} Q_{ins} &\coloneqq \left( 20 \cdot \frac{kW}{m^2} \right) & \text{Heat load for insulated surfaces} \\ Q_{uns} &\coloneqq \left( 38 \cdot \frac{kW}{m^2} \right) & \text{Heat load for uninsulated} \\ \Delta T_{corr} &\coloneqq \frac{\left( T_{room} - T_{H2} \right)}{T_{room} - T_{He}} = 0.94 & \text{ratio of delta T for H2 heat load} \\ \text{correction. corrects for slightly higher} \\ \text{temperature of H2,D2 when compared to} \end{split}$$

He at the test condition

Total mass evolution rate for loss of IV for H2

$$dm_{H2} \coloneqq \left(Q_{ins} \cdot A_{ins} + Q_{uns} \cdot A_{uns}\right) \cdot \frac{\Delta T_{corr} \cdot K_{H2}}{\lambda_{H2} \cdot K_{He}} = 7.816 \frac{gm}{s}$$

Total mass evolution rate for loss of IV for D2

$$dm_{D2} \coloneqq \left(Q_{ins} \cdot A_{ins} + Q_{uns} \cdot A_{uns}\right) \cdot \frac{\Delta T_{corr} \cdot K_{D2}}{\lambda_{D2} \cdot K_{He}} = 8.683 \frac{gm}{s}$$

Mass evolution rate for loss of IV for He. Note that the mass evolution is much larger than that of H2 and D2 and more relief capacity will be needed for this target fluid. There are no approved plans for He as a target fluid at the time of this calculation.

 $dm_{He} \coloneqq \left( Q_{ins} \cdot A_{ins} + Q_{uns} \cdot A_{uns} \right) \cdot \frac{1}{\lambda_{He}} = 250.958 \ \frac{gm}{s}$ 

Volumetric flow of H2 and D2

$$H2_{scfm} \coloneqq \frac{dm_{H2}}{\rho_{H2std}} = 194.835 \frac{ft^3}{min}$$
 volumetric flow of H2 in scfm

$$D2_{scfm} \coloneqq \frac{dm_{D2}}{\rho_{D2std}} = 108.357 \frac{ft^3}{min}$$
 volumetric flow of D2 in scfm

From the above, comparison between H2 and D2 flow rates indicates that the H2 case will require the most relief capacity. Thus only this case need be considered.

The internal target components are relieved through the branch line of a tee at the base of the condenser. The worst case failure mode is for this branch to be plugged forcing all flow from the condenser and supply line back through the cell. To determine the pressure in the condenser and supply line for this mode the mass flow from only the condenser and supply line are needed.

Mass flow from only loop supply tube and condenser

$$dm_{cond} \coloneqq \left(Q_{ins} \cdot \left(A_{sup} + A_{fill} + A_{cond}\right)\right) \cdot \frac{\Delta T_{corr} \cdot K_{H2}}{\lambda_{H2} \cdot K_{He}} = 2.981 \frac{gm}{s}$$

$$dm_{cell} \coloneqq \left(Q_{ins} \cdot A_{fill} + Q_{uns} \cdot A_{uns}\right) \cdot \frac{\Delta T_{corr} \cdot K_{H2}}{\lambda_{H2} \cdot K_{He}} = 1.853 \frac{gm}{s}$$

$$dm_{ret} \coloneqq Q_{ins} \cdot \left(A_{fill} + A_{rl}\right) \cdot \frac{\Delta T_{corr} \cdot K_{H2}}{\lambda_{H2} \cdot K_{He}} = 2.981 \frac{gm}{s}$$

# Relief of H2 target only:

Pressure drop in relief paths of the target:

Two identical releif valves shall be located on the gas panel. These reliefs shall be considered redundant parallel paths. The ASME allowed pressure rise for this condition is the greater of 16% or 4 psi (UG-125). Stop valves may be in position provided the conditions in VIII D1 M5.6 are met. Each relief valve must exhaust into the hydrogen vent header. This header is maintained at ~1-2 psi above atmospheric pressure with an inert gas to ensure that oxegen is purged from the line. A parallel plate relief is installed at the exit of the header with a set pressure of ~2 psi. An additional line connects the storage tank to the target. The operating pressure of the system is assumed to be 18 psia. The return to the stoage tank outside is not considered as a relief path here.

### Parallel plate relief

Consider first the parallel plate relief at the exit of the vent stack. The critical pressure may be used to determine the nature of the flow at the exit, critical or subcritical. The exit of the vent is to atmosphere at 14.7 psia

$$Pc_{vent} := Rc_{H2} \cdot P_{plate} \cdot 1.1 = 9.698 \ psi$$
 critical pressure vent relief

The exit pressure is larger than the critical pressure thus, the flow is subcritical at this relief. The upstream pressure will be checked to ensure that the assumption of the plate relief pressure is correct. We follow API 520 3.6.3

$K_{valve} \coloneqq 0.62$	Coef of discharge
$D_{plate} \coloneqq 2.245 \cdot in$	most restrictive diameter of relief
$C_{asme} \coloneqq 17.9 \cdot \frac{hr}{kg} \cdot \sqrt{\frac{gm}{K \cdot mol}} \cdot \frac{kN}{m^2} \cdot mm^2$	Coeff determined from ratio k now for subcritical flow
$P_1 := P_{plate} \cdot 1.1 = 18.37 \ psi$	upstream pressure assumed
$P_2 \coloneqq P_{atm} = 14.7 \ psi$	downstream pressure assumed
$r \coloneqq \frac{P_2}{P_1}$	

### TGT-CALC-401-001

$$F_{2} \coloneqq \sqrt{\frac{k_{H2}}{k_{H2} - 1} \cdot r^{\frac{2}{k_{H2}}} \cdot \left(\frac{1 - r^{\frac{k_{H2} - 1}{k_{H2}}}}{1 - r}\right)} = 0.887 \qquad \text{subcritical flow coeff}$$

the required area for the given mass discharge is

$$A_{req} \coloneqq \frac{dm_{H2} \cdot C_{asme}}{F_2 \cdot K_{valve}} \cdot \sqrt{\frac{T_{room}}{M_{H2} \cdot P_1 \cdot (P_1 - P_2)}} = 0.307 \ in^2$$

the required lift of the plate would be

$$h_{lift} \coloneqq \frac{A_{req}}{\pi \cdot D_{plate}} = 0.044 \ in$$

The estimated force on the plate is

$$F_{plate} := (P_1 - P_{atm}) \cdot \pi \cdot \frac{D_{plate}^2}{4} = 14.527 \ lbf$$

Springs must be chosen to provide the given lift height for this force.

### Vent stack pressure drop

Vent stack estimate based on placement of tanks and vent at 100' from building. This is a convient place. NFPA requirement of 40 ft from all buildings and AC vents. Storage tanks to be paced with vent. Flex lines will be needed to connect the vent to the gas panel relief and the relief at the top of the target. The length of these lines is assumed to be 20 ft. The line is assumed to be American BOA Parwrap 1.5" nom hose.

$L_{vent} \coloneqq 200 \cdot ft$	Length of hard vent pipe
$D_{od} \coloneqq 2.375 \cdot in$	2 in pipe nom OD
$t_{wall}$ := 0.065 $\cdot$ in	wall thickness for 2" Sch 5 S pipe
$ID_{vent} \! \coloneqq \! D_{od} \! - \! t_{wall}$	ID of vent pipe
$A_{vent} \coloneqq \frac{\pi \cdot ID_{vent}^2}{4} = 0.003 \ m^2$	cross area of vent stack

$$T_{vent} := 300 \cdot K \qquad P_{vent} := 1.1 \cdot P_{plate} \qquad \text{temp and pressure in vent}$$

$$v_{vent} := \frac{dm_{H2}}{\rho_{H2}(T_{vent}, P_{vent}) \cdot A_{vent}} = 28.239 \frac{m}{s} \qquad \text{velocity in vent line}$$

$$Re_{vent} := \frac{\rho_{H2}(T_{vent}, P_{vent}) \cdot v_{vent} \cdot ID_{vent}}{\mu_{H2300}} = 1.893 \cdot 10^4 \qquad \text{Reynolds number at} \\ relief; flow is \\ turbulent \qquad \text{trubulent}$$

$$f_{vent} := \frac{0.032 \cdot in^{\frac{1}{3}}}{ID_{vent}} = 0.024 \qquad \text{Weymouth friction factor}$$

$$K_{vent} := f_{vent} \cdot \frac{L_{vent}}{ID_{vent}} \qquad \text{resistance coef for vent}$$

$$N_{bends} := 8 \qquad \text{estimated number of street} \\ elbows in vent stack \qquad \text{K}_{etbows} := 60 \cdot f_{vent} = 1.452 \qquad \text{worst case factor for elbows}$$
Flex lines to insertion cart:
$$L_{flex} := (20 \cdot ft) \cdot 3 \qquad \text{effective length of flex line for insertion cart} \\ actual length is 20 ft. The factor of 3 results from measurements of pressure drop in corregated flex hose \qquad ID_{flex} := 1.5 \cdot in \qquad ID of flex lines$$

 $A_{flex} \coloneqq \pi \cdot \frac{ID_{flex}^{2}}{4} \qquad \text{cross area of flex}$   $f_{flex} \coloneqq \frac{0.032 \cdot in^{\frac{1}{3}}}{ID_{flex}^{\frac{1}{3}}} = 0.028 \qquad \text{Weymouth friction factor}$ 

$$v_{flex} \coloneqq \frac{dm_{H2}}{\rho_{H2} (T_{vent}, P_{vent}) \cdot A_{flex}} = 66.971 \frac{m}{s} \quad \text{velocity in flex line}$$

$$K_{flex} \coloneqq f_{flex} \cdot \frac{L_{flex}}{ID_{flex}} = 13.418 \quad \text{resistance coef for flex line}$$

$$\Delta P_{flex} \coloneqq K_{flex} \cdot \rho_{H2300} \cdot \frac{v_{flex}^2}{2} = 0.729 \text{ psi} \quad \text{pressure loss in flex line}$$

$$\beta \coloneqq \frac{ID_{flex}}{ID_{vent}}$$

$$K_{en} \coloneqq \frac{(1 - \beta^2)^2}{\beta^4} = 1.881 \quad \text{Resistance factor for enlargement from flex to main}$$

head loss from height of vent stack

$$h_{stack} \coloneqq 70 \cdot ft$$
 this is negligible  
 $\Delta P_{stack} \coloneqq h_{stack} \cdot g \cdot \rho_{H2} (T_{vent}, P_{vent}) = 0.003 \ psi$ 

total pressure loss in vent line from relief valve exit to parallel plate

$$\Delta P_{vent} \coloneqq \left( K_{vent} + N_{bends} \cdot K_{elbows} \right) \cdot \rho_{H2} \left( T_{vent}, P_{vent} \right) \cdot \frac{v_{vent}}{2} + \Delta P_{flex} = 0.946 \ psi$$

### First stage relief (ASME Relief Valve):

The pressure at the back side of the first stage relief is

$$P_2 \coloneqq P_{plate} \cdot 1.1 + \Delta P_{vent} = 19.316 \ psi$$
pressure on upstream of 1st  
stage relief valve $P_1 \coloneqq P_{set} \cdot 1.1 = 33 \ psi$ upstream pressure assumed $Pc_1 \coloneqq Rc_{H2} \cdot P_{set} \cdot 1.1 = 17.422 \ psi$ critical pressure at 1st stage  
relief

The flow at the 1st stage relief will be subcritical  

$$r:=\frac{P_2}{P_1}$$
ratio of outlet to inlet  
pressures  

$$F_2:=\sqrt{\frac{k_{H2}}{k_{H2}-1}} \cdot r^{\frac{2}{k_{in2}}} \cdot \left(\frac{1-r^{\frac{k_{in2}-1}{k_{in2}}}}{1-r}\right) = 0.747$$
subcritical flow coeff  

$$K_{valve} := 0.878 \cdot 0.9$$
Coef of discharge  

$$D_{plate} := 2.245 \cdot in$$
most restrictive diameter of  
relief  

$$C_{asme} := 17.9 \cdot \frac{hr}{kg} \cdot \sqrt{\frac{gm}{K \cdot mol}} \cdot \frac{kN}{m^2} \cdot mm^2$$
Coeff determined from ratio k  
now for subcritical flow

$$A_{req} \coloneqq \frac{dm_{H2} \cdot C_{asme}}{F_2 \cdot K_{valve}} \cdot \sqrt{\frac{T_{room}}{M_{H2} \cdot P_1 \cdot \left(P_1 - P_2\right)}} = 0.111 \ in^2$$

### **Relief valve:**

Based on the above a Flow Safe F85 Series relief valve 01-4167M-203 with viton seat will be more than adequate for our needs. The pressure at the entrance of the relief is assumed to be.

 $P_{relief} \coloneqq 1.1 \cdot P_{set} = 33 \ psi$ 

# Piping from cell to relief

For all piping from the main relief line tee, located below the condenser, to the relief at the panel the temperatureand pressure of the H2 is assumed to be the same as that at the relief valve. This is a very conservative assumption. Thus the density and volumetric flow are

$$\rho \coloneqq \rho_{H2} \left( T_{vent}, P_{relief} \right) = 0.184 \frac{kg}{m^3}$$

$$dV_{H2} \coloneqq \frac{dm_{H2}}{\rho} = 0.043 \ \frac{m^3}{s}$$

## Piping from Target Top flange to Relief Valve:

The relief valve will be mounted on the gas panel. The gas panel is assumed to be 10 ft from the top of the target by hose. This connection is assumed to be made using 1" nominal flex hose. These lines are named the connection lines. There is also an abrupt enlargement from 3/4" tube to 1 in ID. The flow must pass through a 1" Tee branch to reach the relief valve.

# Flex lines: $L_{cl} := (10 \cdot ft) \cdot 3$ effective length of flex line for connection lines from gas<br/>panel to target is 6 ft. The factor of 3 results from<br/>measurements of pressure drop in corregated flex hose $ID_{cl} := 1 \cdot in$ ID of flex lines $A_{cl} := \pi \cdot \frac{ID_{cl}^2}{4}$ cross area of flex $f_{cl} := \frac{0.032 \cdot in^{\frac{1}{3}}}{ID_{cl}^{\frac{1}{3}}} = 0.032$ Weymouth friction factor $v_{cl} := \frac{dV_{H2}}{A_{cl}} = 83.881 \frac{m}{s}$ velocity in flex line

$$\begin{split} & K_{cl} \coloneqq f_{cl} \cdot \frac{L_{cl}}{LD_{cl}} = 11.52 & \text{resistance coef for flex line} \\ & \Delta P_{cl} \coloneqq K_{cl} \cdot \rho_{122300} \cdot \frac{v_{cl}^2}{2} = 0.982 \ \textbf{psi} & \text{pressure loss in flex line} \\ \hline & \Delta P_{cl} \coloneqq K_{cl} \cdot \rho_{122300} \cdot \frac{v_{cl}^2}{2} = 0.982 \ \textbf{psi} & \text{pressure loss in flex line} \\ \hline & \mathbf{Gas panel:} & \\ & L_{gp} \coloneqq (2 \cdot fl) & \text{estimated length of gas panel tubing to valve} \\ & t_{coull} \equiv 0.035 \cdot \textbf{in} & \\ & OD \coloneqq 1 \cdot \textbf{in} & \\ & ID_{gp} \coloneqq OD - 2 \cdot t_{wall} & ID \text{ of gas panel return tube} \\ & A_{gp} \coloneqq \pi \cdot \frac{D_{gp}^2}{4} & \text{cross area of return tube} \\ & f_{gp} \coloneqq \frac{0.032 \cdot \textbf{in}^{\frac{1}{3}}}{ID_{gp}^{\frac{1}{3}}} = 0.033 & \text{Weymouth friction factor} \\ & v_{gp} \coloneqq \frac{dV_{H2}}{A_{gp}} = 96.983 \ \frac{m}{8} & \text{velocity in return tube} \\ & K_{gp} \coloneqq f_{gp} \cdot \frac{L_{gp}}{ID_{gp}} = 0.846 & \text{resistance return} \\ & K_{tex} \coloneqq 60 \cdot f_{gp} & \text{resistance of tee branch} \\ & K_{ethow} \coloneqq 60 \cdot f_{gp} & \text{resistance of elbow at tgt} \\ & \Delta P_{gp} \coloneqq (K_{tex} + K_{elbout} + K_{gp}) \cdot \rho \cdot \frac{v_{gp}^2}{2} = 0.6 \ \textbf{psi} \end{split}$$



# Internal target piping pressure loss:

Escaping gas from the cell must pass through several piping sections prior to reaching the valve. Some of these sections are inside the OVC and are cold for some portion. From the cell to the tee below the condenser, the escaping gas is assumed to have a temperature of 23.4K and pressure of 33 psi. From the relief tee to the target top flange the assume temperature is 300 K. The worst case failure mode would be for the condenser to relief tee to be blocked while the target vacuum is lost. All flow must then pass through the return side plumbing from the cell.

From relief tee to target top flar	nge
$L_{ret} \coloneqq 3 \cdot ft$	Length of return lines
$D_{ret}$ := 0.75 $\cdot$ in	OD of supply and return lines
$D_{tee} \! \coloneqq \! 0.5 \! \cdot \! in$	nominal diameter of relief tee
$t_{wall}$ := 0.035 $\cdot$ in	wall thickness of lines
$ID_{ret} \! \coloneqq \! D_{ret} \! - \! 2 \boldsymbol{\cdot} t_{wall}$	ID of supply and return lines
$ID_{tee} \! \coloneqq \! D_{tee} \! - \! 2 \boldsymbol{\cdot} t_{wall}$	ID of lines at tee
$A_{ret} \coloneqq \pi \cdot \frac{ID_{ret}^2}{4} = 0.363 \ in^2$	cross area of return
$f_{ret} \coloneqq \frac{0.032 \cdot in^{3}}{ID_{ret}^{\frac{1}{3}}} = 0.036$	Weymouth friction factor (conservative)
$v_{ret} := \frac{dV_{H2}}{A_{ret}} = 181.403 \ \frac{m}{s}$	velocity in return line
$K_{ret} \coloneqq f_{ret} \cdot \frac{L_{ret}}{ID_{ret}} = 1.927$	resistance coef for return line
$K_{elbow}\!\coloneqq\!f_{ret}\!\cdot\!60\!=\!2.183$	resistance coef for miter bends in line assume 2
$\beta \coloneqq \frac{ID_{tee}}{ID_{ret}}$	

$$K_{vn} := \frac{(1-\beta^2)^2}{\beta^4} = 2.252$$
resistance factor for  
enlargement  
pressure loss in ret line to relief valve  

$$\Delta P_{ret} := (K_{ret} + 2 \cdot K_{oblow} + K_{en}) \cdot \rho \cdot \frac{v_{ret}^2}{2} = 3.75 \text{ psi}$$
**Cell to relief tee line**  

$$L_{rt} := 12 \cdot ft$$
Length of line 6 ft plus 2 ft flex  

$$D_{rt} := 0.5 \cdot in$$
OD of supply and return lines  

$$t_{unult} := 0.035 \cdot in$$
wall thickness of lines  

$$ID_{rt} := D_{rt} - 2 \cdot t_{walt}$$
ID of supply and return lines  

$$A_{rt} := \pi \cdot \frac{ID_{rt}^2}{4} = 0.145 in^2$$
cross area of return  

$$\rho_{H22} := 2.81 \cdot \frac{kg}{m^3}$$
density of H2 at 33 psi and  
23.4K (boiling point)  

$$f_{rt} := \frac{dn_{H2}}{D_{rt}^4} = 0.042$$
Weymouth friction factor  
(conservative)  

$$v_{rt} := \frac{dn_{H2}}{A_{rt} \cdot \rho_{H2}} = 29.688 \frac{m}{8}$$
velocity in return line  

$$K_{vlow} := f_{rt} \cdot 20 = 0.848$$
resistance coef for return  

$$\lim e$$

$$K_{vlow} := f_{rt} \cdot 20 = 0.848$$
resistance coef for short radius  
r = 0 bends in line assume 2  
K\_{vee} := f\_{rt} \cdot 60
resistance coef for branch line at tee

pressure loss in ret line to relief valv	e
$\Delta P_{rl} \coloneqq \left( K_{rl} + 2 \cdot K_{elbow} + K_{tee} \right) \cdot \rho_H$	$v_2 \cdot \frac{v_{rl}^2}{2} = 3.311 \ psi$
loss from cell legs	
$L_{leg} \coloneqq 5 \cdot in$	Length of leg
$D_{leg} \coloneqq 0.375 \cdot in$	OD of leg
$t_{wall} \coloneqq 0.035 \cdot in$	wall thickness of line
$ID_{leg} \! \coloneqq \! D_{leg} \! - \! 2 \boldsymbol{\cdot} t_{wall}$	ID of leg
$A_{leg} \coloneqq \pi \cdot rac{ID_{leg}^{2}}{4} = 0.073 \ in^{2}$	cross area of leg
$ \rho_{H2} \coloneqq 2.81 \cdot \frac{kg}{m^3} $	density of H2 at 33 psi and 23.4K (boiling point)
$f_{leg} \coloneqq \frac{0.032 \cdot in^{\frac{1}{3}}}{ID_{leg}^{\frac{1}{3}}} = 0.048$	Weymouth friction factor (conservative)
$v_{leg} \! \coloneqq \! rac{dm_{H2}}{A_{leg} \! \cdot \!  ho_{H2}} \! = \! 59.009 \; rac{m}{s}$	velocity in leg
$K_{leg} \coloneqq f_{leg} \cdot \frac{L_{leg}}{ID_{leg}} = 0.779$	resistance coef for leg
$\beta := \frac{ID_{leg}}{ID_{rl}}$	
$K_{en} \! \coloneqq \! \frac{\left(1\!-\!eta^2 ight)^2}{eta^4} \! = \! 0.975$	resistance factor for enlargement
$\Delta P_{leg} \coloneqq \left( K_{leg} + K_{en} \right) \cdot \rho_{H2} \cdot \frac{v_{leg}^{2}}{2} =$	: 1.245 <i>psi</i>

nd condenser only. The entrance to the le	eg tube is also acounted for
annulus exit from cell	
$D_{in} \coloneqq \frac{(0.738 \cdot in + 0.906 \cdot in)}{2} = 0.822$	<i>in</i> avg small diameter of anulus
$D_{out} \coloneqq (0.479 + 0.516) \cdot in = 0.995 \ in$	avg large diameter of anulus
$P_{in} \coloneqq D_{in} \cdot \pi$	average perimeter inner
$P_{out} \coloneqq D_{out} \cdot \pi$	average perimeter outer
$A \coloneqq \frac{\pi}{4} \cdot \left( D_{out}^2 - D_{in}^2 \right) = 0.247 \ in^2$	flow area
$D_h \coloneqq \frac{4 \cdot A}{\left(P_{in} + P_{out}\right)} = 0.173 \ in$	hydraulic diameter
$ ho_{H2}$ :=2.81 $\cdot rac{kg}{m^3}$	density of H2 at 33 psi and 23.4K (boiling point)
$f_{cell} \coloneqq \frac{0.032 \cdot in^{\frac{1}{3}}}{D_h^{\frac{1}{3}}} = 0.057$	Weymouth friction factor (conservative)
$v_{cell} \coloneqq \frac{dm_{cond} + dm_{cell}}{\pi \cdot \frac{D_h^2}{4} \cdot \rho_{H2}} = 113.446 \frac{m}{s}$	velocity in cell annulus
$K_{cell} \coloneqq f_{cell} \cdot \frac{2.8 \cdot in}{D_h} = 0.929$	resistance coef for leg
$\beta \coloneqq \frac{ID_{leg}}{D_{b}} = 1.763$	ratio for contraction to 3/8

$$\begin{aligned} & K_{cont} \coloneqq 0.5 \cdot \frac{(1-\beta^2)}{\beta^4} \\ \text{estimate of pressure drop in cell annulus and exit} \\ & \Delta P_{coll} \coloneqq (K_{coll} + K_{cont}) \cdot \rho_{H2} \cdot \frac{v_{coll}^2}{2} = 2.152 \ psi \end{aligned}$$
**Total maximum cell pressure:**
Max total cell absolute pressure from the above calculations and assumptions
 $P_{coll} \coloneqq \Delta P_{coll} + \Delta P_{rot} + \Delta P_{rl} + \Delta P_{log} + P_{roliof} + \Delta P_{exl} = 45.209 \ psi \end{aligned}$ 
**Loss in supply line**
 $L_{aup} \coloneqq 12 \cdot ft$ 
Length of leg 6 ft + 2 ft of flex
 $D_{aup} \coloneqq 0.25 \cdot in$ 
OD of leg
 $t_{wall} \coloneqq 0.035 \cdot in$ 
wall thickness of line
 $ID_{mp} \coloneqq 0.25 \cdot in^2$ 
cross area of leg
 $\rho_{H2} \coloneqq 2.81 \cdot \frac{kg}{m^3} = 0.025 \ in^2$ 
cross area of leg
 $\rho_{H2} \coloneqq 2.81 \cdot \frac{kg}{m^3} = 0.057$ 
Weymouth friction factor
 $ID_{sup} \coloneqq \frac{dm_{cond}}{d_{aup} \cdot \rho_{H2}} = 64.629 \ \frac{m}{s}$ 
velocity in leg

### TGT-CALC-401-001

